



Bartovation LLC.
2483 47th St.
Astoria, NY 11103
contact@bartovation.com
(707) 255-2029

CERTIFICATE OF ANALYSIS

Product Code: PCL02V50

Product Description: Low Level Chlorine Test Strips 0-10 ppm

Lot Number: As Stated | **Expiration Date:** As Stated

Application: The 0-10 ppm Chlorine test strip is used to detect available (free) chlorine at level usually associated with potable water. The test strip can be used to monitor the level at a point of use source (tap). The strip can also be used by water treatment facilities to monitor available chlorine levels in water being discharged through a community system. An additional application involves using the strip in conjunction with field-based water purifying systems.

Test Range: 0-10 ppm

Test Increments: Color charts calibrated at 0, 0.5, 1, 3, 5, and 10 ppm

Accuracy: +/- 1/2 color chart unit

Detection Limit: 0.25 ppm

Storage Recommendations: Store in original packaging in a cool (20-30C), dry, place out of direct sunlight.

Shelf-Life: Two years from date of manufacture when stored properly in original packaging.

Interferences: Test strip may react to other oxidizing materials, peracetic acid, peroxide, etc.

Instructions for Use: Follow the label instructions for the color chart being used.

Chemistry Behind the Test: The test pad is treated with a formula consisting of buffers, surfactants, and red-ox indicators. The presence of free chlorine in a sample causes the red-ox indicator in the test pad to develop color. The intensity of the color developed is proportional to the amount of free chlorine present.

Other Information: The Low Level Chlorine test strips were developed to work with solutions prepared from concentrated solutions of sodium hypochlorite.

Disclaimer: The Low Level Chlorine test strips are not intended for use to diagnose, treat, or monitor any medical condition.